

LT Panel Boards



An Energy Saving Equipment



Makpower Transformers Pvt. Ltd.

33/1. N.S.Road, 2nd Floor, Room No. 235

Marshall House, Kolkata - 700 001

Call : 2231 3141, Tele-fax : 2221 3142

Website: www.makpowertransformers.com

- Power Control Centre
- Motor Control Centre
- Automatic Power Factor Controller
- Auto Mains Failure
- Panel Bus Ducts
- VVF Drive Panels
- Soft Starter Panel

Satisfied Customers

Name of the Firm	Transformers Specification	Nos.
R. D. TEA CO. LTD Hansqua Tea Garden Darjeeling, West Bengal	PDB with 1250 amps Aluminium bus bar having incoming 1250A ACB of 1 no. & 12 nos. 400A SP HRC fuse base	1
GKB RX LENS (P) LTD. Kolkata	500A Aluminium bus bar having incoming 630 A MCCB - 1 no. & Outgoing 200A MCCB - 4 nos. 125A MCCB-1 no. 100A MCCB - 2 no. & 1 nos. COS 250A	1
LA MARTINIERE SCHOOL (GIRLS) 11, U. N. Brahmachari Street Kolkata	PDB with 1000A Aluminium bus bar having incoming 800A ACB of 1 no. & outgoing 125A SFU - 4 nos., 200A SFU - 4 nos. & 400A SFU - 4 nos.	1
JAYA CINEMA Lake Town, Kolkata	PDB with 600A copper bus bar having incoming 400A MCCB and outgoing SFU	1
EASTERN RAILWAY Barasat Carshed	PDB with 2000A copper bus bar having 2 nos, 1250A ACB as incomer & MCCB's as outgoing feedwes.	1
HOOGLHY MILLS PROJECTS LIMITED Unit: Mangalpur Jute Mill Durgapur	PDB with 4000 amps copper bus bar having 4000 amps ACB. as Incoming & 4 nos. 1250 amps ACB as outgoing with meters.	1
CRESCENT MANUFACTURING PVT. LTD. Bankura, Bishnupur West Bengal	PDB with 3000 amps Aluminium bus bar having 2500 amps ACB as incoming & 2 nos. 1250 amps ACB as outgoing with meters	1
Space Matrix Agencies (P) Ltd. 11, Clive Row Kolkata - 700001	PDB with 2000A copper bus bar having 1600A ACB as incomer & MCCB's as outgoing feeders with metering Connection.	1
Japfa Comfeed (I) Ltd. P.O. Rakhajungle, Nimpura Kharagpur, West Bengal	PDB with 2000A Aluminium bus bar having 2000AACB as incomer & MCCB's as outgoing feeders & metering connections.	2
Burger Paints India Ltd. Shibpur, Howrah	MCC with 400 amps MCCB as incoming and various rated outgoing feeders with remote control arrangements	1
Air Port Authority Of India NBCBI Airport Kolkata	L & T make APFC Panel for 3 ph, 440V, 50 Hz. 100 KVAR rating	2
Berger Auto Industrial Coatings Ltd. Rishra, Hooghly	L & T make APFC Panel for 3 ph, 440V, 50 Hz. 50 KVAR rating1	1

Name of the Firm	Transformers Specification	Nos.
ICICI Bank Ltd. 3A, Gurusaday Road Kolkata	L & T make APFC Panel for 3 ph, 440V, 50 Hz. 250 KVAR rating	1
Lux 39, Kali Krishna Tagore Street Kolkata	L & T make APFC Panel for 3 ph, 440V, 50 Hz., AC Supply of 70 Kvar rating	1
Jai Balaji Group 15, Bentinck Street Kolkata	Makpower brand 300 Kvar capacitor Bank, 12 Stage of 25 Kbar capacitor with APFC controller.	2
Kohinoor Steel (P) Ltd. Jamshedpur		1
Surya Alloys (P) Ltd. Barjora		1
Diamond Group Kolkata		1
Lhaki Cement BhuttanBarasat Carshed		1